


NOTE:

1. BASE THICKNESS AND REINFORCING VARIES WITH TRAFFIC, CLIMATE, AND SUBGRADE CONDITIONS.
2. CONCRETE BASE MINIMUM 2% SLOPE FROM CENTERLINE TO CURB.
3. DO NOT USE DRAIN HOLES TO SUBGRADE WHEN WATER TABLE IS LESS THAN 2' (0.6 M) FROM TOP OF SUBGRADE. DRAIN TO CATCH BASINS.



CROSSWALK ON CONCRETE BASE

DRAWING NO.	ICPI-12
SCALE	F.S.